

**BOEING****SECURITY FIRE PROTECTION INCIDENT REPORT**

JTC

TIME OUT 10:22 am		TIME IN 12:40 pm		TIME OF INCIDENT 10:22 am		NO. OF MEN 7		REPORT NO. R9-0199			
DATE 6-6-89	DAY Tuesday	SHIFT 1st	PLANT Renton	BUILDING 10-71	FLOOR 2nd	COLUMN B-2					
ORG. NO.	ORG. NAME		SUPERVISOR				PHONE				
NATURE OF INCIDENT: <b>HAZARDOUS CONDITION:</b> Received notification that a lab technician was conducting a test mixing sulfuric acid into 3 beakers with 50 milliliters of hydrogen peroxide. The laboratory fume hood ventilation system malfunctioned causing toxic fumes to be emitted into the lab area. Employees immediately evacuated the laboratory area. City of Rtn. Fire Dept. was notified. Upon their arrival they ordered the entire building be evacuated. Approximately 400 Boeing employees were evacuated for 2 hours due to possible fume migration. Renton city and Boeing personnel donned air pak's and level "A" protective clothing, and entered the laboratory to take ( OVER )											
CAUSE OF INCIDENT:											
CORRECTIVE ACTION/SERVICE:											
TYPE OF INJURIES SUSTAINED:											
FIRE LOSSES		VALUE OF PROPERTY			PER:						
PRODUCTION MANHOURS					PER:						
EQUIPMENT USED:		Engine #20, Car #200, Car #28, Tkr. #27					EXTNG AGENT				
FIRE PERSONNEL		A. Swanson, A. Grover, J. Scott, G. Simpson, Lt. L. Strong, Chief J. V. Johnston, Lt. J. Langer									
FIRE BRIGADE PERSONNEL											
MUTUAL AID COS. RESPONDING EQUIPMENT		City Of Rtn. Tukwila Haz Mat Team 1-ladder, 2-Engs, 2-Haz Mat Vans, 1-Aid Unit, 1-Batt Chief, 1-Chief									
HOW WAS ALARM RECEIVED?		<input type="checkbox"/> ADT		<input checked="" type="checkbox"/> BUSINESS PHONE		<input type="checkbox"/> GUARD		<input type="checkbox"/> VERBAL		<input type="checkbox"/> RADIO	
DISCOVERED BY	EMP. NAME	Unknown				CLOCK NO.	ORG.	PHONE			
REPORTED BY	Same as above				CLOCK NO.	ORG.					
A.D.T. ALARM (TYPE)		TIME		RESET							
NO. OF SPRINKLER HEADS FUSED		NO. OF RISERS AFFECTED		CLOSED:		FROM		TO			
FOLLOW-UP INVESTIGATION		<input type="checkbox"/> YES		<input type="checkbox"/> NO		FOLLOW-UP					
RECOMMENDATIONS											
DATE 6-6-89		SIGNATURE <i>J. Langer</i> J. Langer			TITLE Lt.		PHONE 7-2880				